

Map ID
Direction
Distance
Elevation

MAP FINDINGS

EDR ID Number
EPA ID Number

BN329 POLE # 28638
NW 2522 WEST 16TH ST BY AVE Y
1/2-1 BROOKLYN, NY
0.534 mi.
2821 ft. Site 1 of 2 in cluster BN

NY Spills S110750777
N/A

Relative:
Higher

Actual:
9 ft.

SPILLS:

Name: POLE # 28638
Address: 2522 WEST 16TH ST BY AVE Y
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 1009410 / 2011-01-25
Facility ID: 1009410
Facility Type: ER
DER Facility ID: 397901
Site ID: 442946
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 2401
Spill Date: 2010-12-02
Investigator: RWAUSTIN
Referred To: Not reported
Reported to Dept: 2010-12-02
CID: Not reported
Water Affected: Not reported
Spill Source: Unknown
Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2010-12-02
Spill Record Last Update: 2011-01-25
Spiller Name: Not reported
Spiller Company: CON ED
Spiller Address: Not reported
Spiller Company: 999
Contact Name: ERT
DEC Memo: "1/25/11 - Austin - Pole transformer leaked onto pavement - Con Ed contained and cleaned up the spill - see eDocs for more information -

Remarks: Spill closed - end "
"cleanup pending - also on tree"

All Materials:

Site ID: 442946
Operable Unit ID: 1193440
Operable Unit: 01
Material ID: 2188824
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: .25
Units: G
Recovered: Not reported
Oxygenate: Not reported